

> REPLACE THIS LINE WITH YOUR MANUSCRIPT ID NUMBER (DOUBLE-CLICK HERE TO EDIT) <

International Round Robin Test of Critical Current of Superconducting Cable Sample

T. Matsushita, M. Kiuchi, T. Masuda, S. Mukoyama, K. Funaki, J. Cho, J. Lu, M. J. Raine, L. Quéval, F. Trillaud, G. Zhang, M. Song, J. Zheng, Z. Chen, and J. Li

Abstract— Ten institutes from six countries participated in an international round-robin test to evaluate the critical current of a superconducting power cable made of Bi-2223 tapes. The cable design featured a two-layer inner core conductor and a single-layer outer shield conductor. The shield layer measured approximately 40 mm in diameter, and the cable length was 2 meters. To eliminate the influence of resistive voltage drops from current transfer, voltage taps for measurement were positioned at a sufficient distance from the current terminals. The critical current was determined using the resistive method with the electric field criterion of 1.0 $\mu\text{V}/\text{cm}$. Additionally, the n -value, an optional parameter reflecting the current-voltage ($I - V$) characteristics, was extracted from the $I - V$ curve within an electric field range of 0.1 to 1.0 $\mu\text{V}/\text{cm}$. A detailed uncertainty analysis was conducted for both the critical current and the n -value. Finally, the paper discusses the potential for standardization of the employed resistive measurement method.

Keywords—critical current, n -value, superconducting cable, experimental standard deviation, round robin test

I. INTRODUCTION

The growing threat of global warming due to CO_2 emission is exacerbated by the anticipated surge in electricity consumption from data centers fueled by AI advancements. High-temperature superconducting (HTS) power cables offer a promising solution, particularly for data centers, because of their zero power transmission loss in direct current. Extensive research and development efforts have been undertaken on HTS cables [1-14], alongside numerous demonstration projects to identify real-world challenges [15-22].

Manuscript received ??????

T. Matsushita and M. Kiuchi are with Kyushu Institute of Technology, Iizuka, Fukuoka 820-8502, Japan (e-mail: matsushita391teruo@outlook.jp, kiuchi@phys.kyutech.ac.jp)

T. Masuda is with Sumitomo Electric Industries, Ltd., Konohana-ku, Osaka 554-0024, Japan (e-mail: masuda-takato@sei.co.jp).

S. Mukoyama is with Furukawa Electric Co., Hiratsuka, Kanagawa 254-0016, Japan (e-mail: tc90mukoyama@jcma.jp).

K. Funaki is with Kyushu University, Nishi-ku, Fukuoka 819-0395, Japan (e-mail: funaki.kazuo.681@m.kyushu-u.ac.jp).

J. Cho is with Korea Electrotechnology Research Institute, Changwon, Gyeongsangnam-do, Korea (e-mail: jwcho@keri.re.kr).

J. Lu is with National High Magnetic Field Laboratory, Tallahassee, Florida, The United States (e-mail: junlu@magnet.fsu.edu).

M. J. Raine is with Durham University, Durham, England (e-mail: m.j.raine@durham.ac.uk).

Recognizing the need for standardized testing procedures during ongoing in-grid deployments, Working Group B1.31 of the International Council on Large Scale Electric Systems (CIGRE) published a report in 2013 recommending various testing methods for superconducting cables, including critical current measurement [23]. This recommendation was followed by the International Electrotechnical Commission's (IEC) publication of an international standard in 2018 for testing methods and requirements on HTS-AC power cables and their accessories. The standard also highlighted the need for a standardized DC critical current test method [24]. A three-year (2018-2021) Japanese project aimed to address challenges in standardizing critical current test methods and carried out national round robin testing using two Bi-2223 superconducting cables. An additional parameter characterizing the cable, the n -value, was also measured. Three Japanese institutions participated in this initial test and the results of the test are reported in [25].

The domestic test demonstrated the suitability of the employed resistive measurement method as a standard, with experimental standard deviations for critical current ranging from 0.2 to 1.3 % for both cable layers. However, the limited number of participants necessitated an expanded international test. The COVID-19 pandemic in 2020 initially delayed the international round-robin test due to the logistics in shipping the cable. In 2021, sample cable B from the domestic test was sent internationally, but unfortunately, it was damaged in the test and needed replacement. Finally, in 2022 and 2023, an international round robin test using sample cable C was successfully conducted with participation from 10 institutes across 6 countries: Sumitomo Electric Industries, Ltd. (Japan), Furukawa Electric Co. (Japan), Kyushu Institute of Technology

L. Quéval is with University of Paris-Saclay, Paris, 91192, Gif-sur-Yvette, France (e-mail: loic.queval@gpeps.centralesupelec.fr).

F. Trillaud is with the Instituto de Ingeniería, Universidad Nacional Autónoma de México, Ciudad de México 04510, México (e-mail: ftrillaudp@ii.unam.mx).

G. Zhang is with Institute of Electrical Engineering, Chinese Academy of Sciences, Beijing, China (e-mail: gmzhang@mail.iee.ac.cn).

M. Song is with Guangdong Power Grid Co., Ltd., Guangdong, China (e-mail: 5487100@qq.com).

J. Zheng is with Institute of Plasma Physics, Chinese Academy of Sciences, Anhui, China (e-mail: jxzheng@ipp.ac.cn).

Z. Chen is with Shanghai International Superconductor Technology Co., Ltd., Shanghai, China (e-mail: chenzhijue@secrri.com).

J. Li is with Institute of Physics, Chinese Academy of Sciences, Beijing, China (lijie@iphy.ac.cn).

> REPLACE THIS LINE WITH YOUR MANUSCRIPT ID NUMBER (DOUBLE-CLICK HERE TO EDIT) <

(Japan), Korea Electrotechnology Research Institute (Korea), National High Magnetic Field Laboratory (USA), Durham University (UK), University Paris-Saclay (France), Guangdong Power Grid Co., Ltd. (China), Institute of Plasma Physics (China), and Shanghai International Superconductor Technology Co., Ltd. (China).

II. EXPERIMENTS

The superconducting cable C, wound using Bi-2223 tapes of 4.0 mm in width, was used for the measurements. Figure 1 represents the overall structure of the cable, and a cross-sectional diagram detailing the internal arrangement is shown in Fig. 2. The cable featured the core conductor composed of two superconducting tape layers and the single-layer outer shield conductor. The total length was 2.0 m. The inner core and outer shield were separated by an insulator layer for electrical insulation. The solid structure was employed to ensure safe transportation to participating institutes abroad. TABLE I provides a detailed breakdown of the cable structure. "S" and "Z" denote the right-hand and left-hand twist directions of the tapes within each layer, respectively. The number of tapes used for the first and second layers of the inner core was 14 and 15, respectively, while the outer shield utilizes 26 tapes. The current terminals, constructed from copper blocks, were attached to the 4.25 mm thick copper sheath encasing the superconducting tapes.

The voltage taps were peripherally attached on every superconducting tape of the surface layer for both the inner core and outer shield, as indicated by the blue line in Fig. 3 [26]. The distance maintains 5 mm from the edge of the copper sheath to eliminate the influence of the resistive voltage due to current transfer [26]. Although the voltage taps are not directly connected to the inner layer of the core, the electric potential of each layer is considered to be equivalent between the two layers due to the absence of current transfer as will be shown later.

Measurements were conducted on both the inner core and outer shield of the sample cable. Achieving a stable operational



Fig. 1. Measured sample cable. The silver part in the central area is the outer shield conductor. Four copper plates at the both ends are attached to the inner core and to the shield layer.




Fig. 2. Cross-section of the cable.

state necessitated sufficient cooling in liquid nitrogen. Figure 4 displays the results of a preliminary test on the critical current

TABLE I. Structure of the sample cable

	Layer	No. of tapes	Winding	Pitch [mm]	Diameter [mm]
Core	1st	14	S	250	22
	2nd	15	Z	320	23
Shield	Single	26	S	600	40




Fig. 3. Arrangement around the current terminal of the cable core.






Fig. 4. Observed critical current of the cable core as a function of the time after immersing the cable in liquid nitrogen bath.



(a)



(b)

Fig. 5. Current vs. electric field curve of the cable core measured in National High Magnetic Field Laboratory in the United States.

> REPLACE THIS LINE WITH YOUR MANUSCRIPT ID NUMBER (DOUBLE-CLICK HERE TO EDIT) <

TABLE II. I_c value of (a) the inner core and (b) the outer shield. s_i and s_{ri} are experimental standard deviation and its relative value in each institute.

Institute	Measured Value [A]			Average [A]	s_i [A]	s_{ri} [%]
	1st	2nd	3rd			
Sumitomo	4337	4337	4347	4340	6	0.1
Furukawa	4389	4358	4419	4389	31	0.7
Kyushu I. T.	4340	4343	4337	4340	3	0.1
KERI	4292	4295	4299	4295	4	0.1
NHMFL	4307	4305	4307	4306	1	0.0
Durham U.	4387	4385	4386	4386	1	0.0
U. Paris-Saclay	4380	4389	4393	4397	7	0.2
Guangdon P. G.	4315	4329	4303	4316	13	0.3
I. Plasma Phys.	4320	4318	4325	4321	4	0.1
Shanghai I. S. T.	4281	4286	4292	4286	6	0.1

Institute	Measured Value [A]			Average [A]	s_i [A]	s_{ri} [%]
	1st	2nd	3rd			
Sumitomo	3946	3966	3976	3963	15	0.4
Furukawa	3990	3991	3998	3993	4	0.1
Kyushu I. T.	4060	4074	4069	4068	7	0.2
KERI	4014	4023	4027	4021	7	0.2
NHMFL	4050	4059	4058	4056	5	0.1
Durham U.	4140	4140	4148	4143	5	0.1
U. Paris-Saclay	4088	4117	4118	4108	17	0.4
Guangdon P. G.	4062	4075	4085	4074	12	0.3
I. Plasma Phys.	4010	4030	4040	4025	15	0.4
Shanghai I. S. T.	4039	4042	4039	4040	2	0.0

of the inner core as a function of time after immersion in the liquid nitrogen bath. This test demonstrates the time required for the inner core and outer shield to reach the liquid nitrogen temperature, which is approximately 90 minutes and 40 minutes, respectively. Each participating institute employed a current sweep rate optimized for their measurement setup, ranging from a DC (0 A/s) condition for a stepwise change to a maximum around 300 A/s. Figure 5(a) and (b) depict the current vs. electric field curves obtained by the High Magnetic Field Laboratory in the USA for the inner core and the outer shield, respectively, at a sweep rate of 36 A/s. Resistive voltage was not observed and we can conclude that no current transfer occurred [26].

The critical current at the reference temperature of 77.30 K, denoted as $I_c(0)$, was determined from the measured critical current using the following equation [27]:

$$\frac{I_c(\Delta T)}{I_c(0)} = 1 - 0.05082\Delta T, \quad (1)$$

where $\Delta T = T - 77.30$. The n value was additionally measured within the electric field range of 0.1 to 1.0 $\mu\text{V}/\text{cm}$. Each measurement was repeated three times.

III. RESULTS AND DISCUSSION

TABLE II summarizes the critical current measurements for the inner core and outer shield obtained by each participating institute. The relative experimental standard deviations (s_{ri}) are generally low across all institutes, with most values falling below 0.4 %. This level of deviation is likely attributable to the uncertainty associated with the instruments used in the experiment. Similarly, TABLE III shows that the relative experimental standard deviations for the n -value are also low across all institutes.

TABLE IV presents the critical currents and n -values for the inner core and outer shield as determined by all participants. The n -value obtained for the outer shield by French institute exhibits a significant deviation. This can be attributed to the fitting process using the n -value model within an electric field range exceeding 1.0 $\mu\text{V}/\text{cm}$. Consequently, this value was excluded from the statistical analysis. Although larger than the values observed within individual institutes, the overall relative experimental standard deviations remained acceptable, reaching 0.90 % and 1.3 % for the inner core and outer shield, respectively. Conversely, the experimental standard deviations for the n -value were considerably higher, reaching 11.1 % and 15.4 % for the inner core and outer shield, respectively. These values are consistent with the results reported in the previous domestic round robin test [25].

We now investigate the uncertainty associated with the critical current measurement. Based on the n -value model, the critical current can be expressed as:

$$I_c = I_0(T_0) = \left[I(V) \left(\frac{E_c l}{V} \right)^{1/n} \right]_{V=E_c l}, \quad (2)$$

where $E_c = 1.0 \times 10^{-4}$ V/m is the electric field criterion and l denotes the distance between the voltage taps. Assuming a uniform distribution for the deviation of the measured temperature with a distribution width of $2\delta T$, the relative standard uncertainty stemming from temperature measurement using Eq. (1) can be calculated as:

$$u_{rT} = \frac{0.05082\delta T}{\sqrt{3}} \approx 0.029\delta T. \quad (3)$$

The relative standard uncertainties of the critical current arising from the current source, voltmeter, and distance between the voltage taps can be expressed as:

> REPLACE THIS LINE WITH YOUR MANUSCRIPT ID NUMBER (DOUBLE-CLICK HERE TO EDIT) <

TABLE III. n value of (a) the inner core and (b) the outer shield.

Institute	Measured Value			Average	s_i	s_{ri} [%]
	1st	2nd	3rd			
Sumitomo	20.0	21.0	21.0	20.7	0.6	2.8
Furukawa	21.3	22.1	22.2	21.9	0.5	2.3
Kyushu I. T.	20.0	21.0	20.2	20.3	0.6	2.9
KERI	20.3	20.9	21.9	21.0	0.8	3.8
NHMFL	25.8	25.6	25.9	25.8	0.1	0.5
Durham U.	25.1	26.3	25.7	25.7	0.6	2.3
U. Paris-Saclay	24.2	22.3	21.9	22.8	1.2	5.3
Guangdon P. G.	18.9	19.2	18.9	19.0	0.2	1.1
I. Plasma Phys.	20.9	20.0	20.3	20.4	0.8	3.9
Shanghai I. S. T.	19.4	19.1	19.7	19.4	0.3	1.5

Institute	Measured Value			Average	s_i	s_{ri} [%]
	1st	2nd	3rd			
Sumitomo	7.0	7.0	7.0	7.0	0	0
Furukawa	8.2	8.2	8.5	8.3	0.2	2.1
Kyushu I. T.	7.6	7.5	7.6	7.6	0.1	0.9
KERI	9.9	9.6	9.5	9.7	0.2	2.1
NHMFL	7.3	7.3	7.3	7.3	0	0
Durham U.	7.4	7.6	7.3	7.4	0.1	2.1
U. Paris-Saclay	11.0	12.7	12.7	12.1	1.0	8.3
Guangdon P. G.	6.7	6.5	6.4	6.5	0.2	3.1
I. Plasma Phys.	9.4	9.6	9.7	9.6	0.2	2.1
Shanghai I. S. T.	6.8	6.7	6.7	6.7	0.1	1.5

TABLE IV. Critical current and n -value.

Institute	Inner core		Outer shield	
	I_c [A]	n -value	I_c [A]	n -value
Sumitomo	4340	20.7	3963	7.0
Furukawa	4389	21.9	3993	8.3
Kyushu I. T.	4340	20.3	4068	7.6
KERI	4295	21.0	4021	9.7
NHMFL	4306	25.8	4056	7.3
Durham U.	4386	25.7	4143	7.4
U. Paris-Saclay	4387	22.8	4108	(12.1)*
Guangdon P. G.	4316	19.0	4074	6.5
I. Plasma Phys.	4321	20.4	4027	9.6
Shanghai I. S. T.	4286	19.4	4040	6.7
Average	4337	21.7	4049	7.8
s	39	2.4	53	1.2
s_r [%]	0.90	11.1	1.3	15.4

*The n -value was measured in the electric field range above 1.0 $\mu\text{V}/\text{cm}$, and this value is not included in the statistical analysis.

$$u_{rI} = \frac{\delta I}{\sqrt{3}I}, \quad u_{rV} = \frac{\delta V}{\sqrt{3nV}}, \quad u_{rl} = \frac{\delta l}{\sqrt{3nl}}, \quad (4)$$

$$u_r = \left[\frac{1}{3} \left(\frac{\delta I}{I} \right)^2 + \frac{1}{3n^2} \left(\frac{\delta V}{V} \right)^2 + \frac{1}{3n^2} \left(\frac{\delta l}{l} \right)^2 \right]^{1/2}. \quad (6)$$

where $\pm\delta I/I$, $\pm\delta V/V$, and $\pm\delta l/l$ represent the allowable ranges of relative deviation for the current, voltage, and distance between the voltage taps, respectively. Then, the relative uncertainty of the critical current is

$$u_r = (u_{rT}^2 + u_{rl}^2 + u_{rV}^2 + u_{rl}^2)^{1/2}. \quad (5)$$

First, we discuss the experimental standard deviation observed within each institute. Since three measurements are typically performed done in a relatively short period, the temperature variation is likely minimal, even if the absolute temperature is unknown. Therefore, the temperature correction remains consistent across the three measurements. Consequently, the uncertainty u_{rT} due to short-term temperature fluctuations can be disregarded. Under this assumption, the relative standard uncertainty simplifies to:

Given the large value of n , the terms associated with the voltage and distance uncertainties can be neglected. Typically, the allowable deviation for the current measurement is assumed to be 0.5% ($\delta I/I = 0.005$), substituting this value into Eq. (6) yields an uncertainty of approximately $u_r \approx 0.003$ (0.3%). This value originally represents the relative experimental standard deviation among the participating institutes. Since the relative experimental standard deviations arising from repeated measurements within each institute are expected to be smaller than those among the institutes, it is reasonable that most values of s_{ri} are smaller than u_r , as evident in TABLE II.

Now, we discuss the relative experimental standard deviation across all institutes. In this case, we can again safely neglect the relative uncertainties associated with voltage and

> REPLACE THIS LINE WITH YOUR MANUSCRIPT ID NUMBER (DOUBLE-CLICK HERE TO EDIT) <

distance measurements. Therefore, the relative uncertainty becomes:

$$u_r = \left[(0.029\delta T)^2 + \frac{1}{3} \left(\frac{\delta I}{I} \right)^2 \right]^{1/2}. \quad (7)$$

Assuming a half-width of temperature distribution of $\delta T = 0.25$ K, which corresponds to the uncertainty of the temperature of 0.14 K, we have $u_r = 0.008$ (0.80%). This value is close to the obtained experimental standard deviation of 0.90% for the inner core. However, the experimental standard deviation for the outer shield is larger than that of the inner core, which aligns with the findings of the domestic round robin test [25]. This suggests an additional source of standard deviation specific to the outer shield measurements. This discrepancy could potentially be linked to anomalies in the E - I characteristics behavior within the electric field range below $1.0 \mu\text{V}/\text{cm}$, which also explains the lower n -value observed for the outer shield.

The observed anomaly in the outer shield is hypothesized to be caused by a current transfer mechanism. Damaged superconducting tapes within the outer shield may transfer current to intact tapes, inducing an additional flux flow voltage. This implies that the anomaly is dependent on the sweep rate of the applied current \dot{I} . As shown in Fig. 6, the critical current of the outer shield exhibits a significant dependence on \dot{I} , whereas the inner core does not. Using the least squares method, these dependences are expressed as:

$$I_c = 4084(1 - 0.766 \times 10^{-4} \dot{I}) \quad (8)$$

for the shield and

$$I_c = 4336(1 + 0.456 \times 10^{-6} \dot{I}) \quad (9)$$




Fig. 6. Current sweep-rate dependence of the critical current.

for the core. Accounting for the sweep rate dependence, the experimental standard deviations and their relative values for each conductor are presented in TABLE V. Notably, the relative experimental standard deviations are comparably for the two conductors.

For the n -value, the experimental standard deviation (s_i) within each institute is similar for both the inner core and outer shield conductors. However, it is significantly larger than that observed for the critical current. This is likely due to the influence of noise voltage around $0.1 \mu\text{V}/\text{cm}$. The inter-institutes standard deviation (s) for the n -value is considerably larger than the intra-institute standard deviations (s_i). Similar to the critical current measurement, this is likely caused by uncertainties in temperature measurement and variations in the methods used by different institutes to determine the n -value. We further investigated the effect of the current sweep rate on the n -value, yielding the following relationships:

$$n = 22.1(1 - 0.160 \times 10^{-3} \dot{I}) \quad (10)$$

for the core and

$$n = 7.4(1 + 0.377 \times 10^{-3} \dot{I}) \quad (11)$$

for the shield (see Fig. 7). The observed increase in the n -value of the outer shield with increasing sweep rate correlates with the decrease in the critical current. Both phenomena can be attributed to the anomalous voltage increase. In contrast, the absence of such an anomaly in the inner core results in minimal changes to both the critical current and n -value. TABLE V also includes the compensated results for the n -value.

The results clearly demonstrate a significant difference in the n -value between the inner core and outer shield. While the n -




Fig. 7. Current sweep-rate dependence of the n -value.

TABLE V. Change in the experimental standard deviations and the relative values of the critical current and n -value due to the compensation of the effect of the current sweep rate.

Compensation	Inner core				Outer shield						
	I_c	s [A]	s_r [%]	n	s [%]	I_c	s [A]	s_r [%]	n	s [A]	s_r [%]
Without	39	0.9	2.4	11.1	53	1.3	1.2	15.4			
With	39	0.9	2.3	10.7	33	0.8	1.1	14.1			

> REPLACE THIS LINE WITH YOUR MANUSCRIPT ID NUMBER (DOUBLE-CLICK HERE TO EDIT) <

value of the outer shield aligns with values typically observed in short samples, the n -value of the inner core is considerably higher. This is thought to be a consequence of the more rapid temperature rise within the inner core during the resistive state, due to its limited contact with liquid nitrogen [25].

Based on the preceding discussion, establishing a recommended range for the current sweep rate during measurement might be considered. However, such a restriction would likely hinder the adoption of the proposed method, as optimal experimental condition may vary across different institutes. Therefore, we propose to refrain from specifying a recommended sweep rate.

The results obtained for both the inner and outer conductors suggest that the resistive method employed in the round robin test is a suitable candidate for a standardized method to determine the critical current of superconducting cables. A target relative combined uncertainty (target uncertainty) of 3 % with a coverage factor $k = 2$ (corresponding to approximately 96 % confidence within the uncertainty range) appears achievable. As shown in TABLE V, all measured values fall the range of $2u_r$ for the inner and outer conductors. Conversely, we believe further investigation is necessary to establish a standardized measurement method for the n -value of superconducting cables.

IV. CONCLUSION

The international round robin test for critical current measurement of a Bi-2223 superconducting power cable was successfully completed. The achieved experimental relative standard deviations for the critical current at 77.30 K were 0.90 and 1.3 % for the inner and outer conductors, respectively. Uncertainty analysis revealed that the primary contributor to the inter-institute experimental standard deviation was the uncertainty in temperature during the experiment. These findings support the suitability of the resistive method can be recommended as a standardized testing procedure, aiming for a target uncertainty of 3 % with a coverage factor of $k = 2$. Notably, all measured critical current values for both conductors were within the $\pm 3\%$ uncertainty range.

However, the experimental relative standard deviations for the n -value were significantly higher than those observed for the critical current, reaching 11.1% and 23.2% for the inner and outer conductors, respectively. This highlights the need for further investigation to establish a standardized measurement method for the n -value of superconducting cables.

ACKNOWLEDGMENT

The work of L. Quéval was supported in part by the French Organization for Standardization AFNOR/UF TC90, and in part by SuperRail project, funded by the French Government as part of the “Plan de Relance” and the “Programme d’investissements d’avenir”.

REFERENCES

- [1] L. Y. Xiao, S. T. Dai, Y. B. Lin, Z. Y. Gao, F. Y. Zhang, X. Xu and L. Z. Lin, *IEEE Trans. Appl. Supercond.* 17, 1652, 2007.
- [2] J. F. Maguire, F. Schmit, S. Bratt, T. E. Welsh, J. Yuan, A. Allais and F. Hamber, *IEEE Trans. Appl. Supercond.* 17, 2034, 2007.
- [3] C. S. Weber, R. Lee, S. Ringo, T. Masuda, H. Yumura and J. Moscovic, *IEEE Trans. Appl. Supercond.* 17, 2038, 2007.
- [4] S. H. Sohn, J. H. Lim, S. W. Yim, O. B. Hyun, H. R. Kim, K. Yatuska, S. Isojima, T. Masuda, M. Watanabe, H. S. Ryoo, H. S. Yang, D. L. Kim and S. D. Hwang, *IEEE Trans. Appl. Supercond.* 17, 2043, 2007.
- [5] S. Mukoyama, M. Yagi, N. Hirano, N. Amemiya, N. Kashima, S. Nagaya, T. Izumi and Y. Shiohara, *Physica C* 463-465, 1150, 2007.
- [6] M. Yagi, S. Mukoyama, N. Amemiya, S. Nagaya, N. Kashima and Y. Shiohara, *Physica C* 468, 2037, 2008.
- [7] V. E. Sytnikov, V. S. Vysotsky, A. V. Rychagov, N. V. Polyakova, I. P. Radchenko, K. A. Shutov, S. S. Fetisov, A. A. Nosov and V. V. Zubko, *IEEE Trans. Supercond.* 19, 1702, 2009.
- [8] J. H. Lim, S. H. Sohn, H. S. Ryoo, H. O. Choi, H. S. Yang, D. L. Kim, Y. H. Ma, K. Ryu and S. D. Hwang, *IEEE Trans. Appl. Supercond.* 19, 1710, 2009.
- [9] M. Yagi, S. Mukoyama, N. Amemiya, N. Kashima, S. Nagaya and Y. Shiohara, *Supercond. Sci. Technol.* 22, 085003, 2009.
- [10] J. F. Maguire and J. Yuan, *Physica C* 469, 874, 2009.
- [11] S. Mukoyama, M. Yagi, T. Masuda, N. Amemiya, A. Ishiyama, N. Kashima, S. Nagaya, Y. Aoki, M. Yoshizumi, Y. Yamada, T. Izumi and Y. Shiohara, *Physica C* 469, 1688, 2009.
- [12] S. Vyatkin, M. Kiuchi, E. S. Otabe, and T. Matsushita, *IEEE Trans. Appl. Supercond.* 25, 6606207, 2015.
- [13] T. Kitamura, K. Adachi, H. Sugane, T. Nakanishi, Y. Aoki, N. Mido, M. Iwakuma and T. Hasegawa, *J. Phys.: Conf. Ser.* 1054, 012075, 2018.
- [14] J. Li, L. Zhang, X. Ye, F. Xia and Y. Cao, *Earth and Environmental Science* 300, 042020, 2019.
- [15] O. Tønnesen, M. Däumling, K. H. Jensen, S. Kvorning, S. K. Olsen, C. Træholt, E. Veje, D. Willén and J. Østergaard, *Supercond. Sci. Technol.* 17, S101, 2004.
- [16] J. A. Demko, I. Sauers, D. R. James, M. J. Gouge, D. Lindsey, M. Roden, J. Tolbert, D. Willén, C. Træholt and C. T. Nielsen, *IEEE Trans. Appl. Supercond.* 17, 2047, 2007.
- [17] H. Yumura, Y. Ashibe, H. Itoh, M. Ohya, M. Watanabe, T. Masuda and C. S. Weber, *IEEE Trans. Appl. Supercond.* 19, 1698, 2009.
- [18] T. Masuda, H. Yumura, M. Ohya, T. Kikuta, M. Hirose, S. Honjo, T. Mimura, Y. Kito, K. Yamamoto, M. Ikeuchi, R. Ohno, *IEEE Trans. Appl. Supercond.* 19, 1735, 2009.
- [19] J. Maguire, D. Folts, J. Yuan, D. Lindsay, D. Knoll, S. Bratt, Z. Wolff and S. Kurtz, *IEEE Trans. Appl. Supercond.* 19, 1740, 2009.
- [20] N. Fujiwara, H. Hayashi, S. Nagaya and Y. Shiohara, *Physica C* 470, 980, 2010.
- [21] M. Yagi, S. Mukoyama, N. Amemiya, A. Ishiyama, X. Wang, Y. Aoki, T. Saito, T. Ohkuma and O. Maruyama, *Physica C* 471, 1274, 2011.
- [22] F. Maguire, J. Yuan, W. Romanosky, F. Schmidt, R. Soika, S. Bratt, F. Durand, C. King, J. McNamara and T. E. Welsh, *IEEE Trans. Appl. Supercond.* 21, 961, 2011.
- [23] CIGRE Technical Brochures 538, 2013, “Recommendations for testing of superconducting cables,” (ISBN: 978-2-85873-232-6).
- [24] IEC 63075, 2019, “HTS-AC power cables and their accessories – Test methods and requirements”.
- [25] T. Matsushita, M. Kiuchi, G. Nishijima, T. Masuda, S. Mukoyama, Y. Aoki, and A. Nakai, *IEEE Trans. Appl. Supercond.* 31, TASC 3058232, 2021.
- [26] T. Matsushita, M. Kiuchi, G. Nishijima, T. Masuda, S. Mukoyama, and Y. Aoki, *Jpn. J. Appl. Phys.* 60, 123001, 2021.
- [27] IEC 61788-24 Ed. 2, 2018, “Critical current measurement – Retained critical current after double bending at room temperature of Ag-sheathed Bi-2223 superconducting wire.”